Information to identify the model(s) to wh		If function includes heating: Indicate th	=
Indoor unit model name Outdoor unit model name	SRK100ZR-S FDC100VNP	information relates to. Indicated values heating season at a time. Include at lea	
Outdoor unit model name	FDC100VNP	neating season at a time. Include at lea	ist the heating season Average.
Function(indicate if present)		Average(mandatory)	Yes
cooling	Yes	Warmer(if designated)	Yes
heating	Yes	Colder(if designated)	No
Item	symbol value unit	Item	symbol value class
Design load		Seasonal efficiency and energy efficier	ncy class
cooling	Pdesignc 10.0 kW	cooling	SEER 6.60 A++
heating / Average heating / Warmer	Pdesignh 7.2 kW Pdesignh 9.0 kW	heating / Average heating / Warmer	SCOP/A 4.40 A+ SCOP/W 5.60 A+++
heating / Colder	Pdesignh - kW	heating / Colder	SCOP/C
			unit
Declared capacity at outdoor temperature		Back up heating capacity at outdoor to	
heating / Average (-10°C)	Pdc <b>7.2</b> kW	heating / Average (-10°C)	elbu 0 kW
heating / Warmer (2°C) heating / Colder (-22°C)	Pdc <b>9.0</b> kW Pdc <b>-</b> kW	heating / Warmer (2°C) heating / Colder (-22°C)	elbu
meating / Colder ( 22 C)	1 dc   -  NY	meating / Colder ( 22 C)	eibu - Kvv
Declared capacity for cooling, at indoor temperature 27(19)°C and  Declared energy efficiency ratio, at indoor temperature 27(19)°C and			
outdoor temperature Tj	D	outdoor temperature Tj	FED.
Tj=35°C Ti=30°C	Pdc 10.00 kW Pdc 7.37 kW	Tj=35°C    Ti=30°C	EERd 3.24 - EERd 5.00 -
Tj=25°C	Pdc 7.37 kW Pdc 4.74 kW		EERd <b>5.00</b>
Tj=20°C	Pdc <b>3.52</b> kW	Tj=20°C	EERd 12.00 -
Declared capacity for heating / Average season, at indoor    Declared coefficient of performance / Average season, at indoor			
temperature 20°C and outdoor temperature $T_j = -7$ °C	re Ij Pdh <b>6.37</b> kW	temperature 20°C and outdoor temperature Ti=-7°C	ature IJ COPd <b>2.70</b> -
Tj=2°C	Pdh <b>3.88</b> kW	∏i=2°C	COPd <b>4.40</b> -
Tj=7°C	Pdh <b>3.39</b> kW	Tj=7°C	COPd <b>6.11</b> -
Tj=12°C	Pdh <b>3.95</b> kW	Tj=12°C	COPd <b>7.39</b> -
Tj=bivalent temperature	Pdh <b>7.20</b> kW	Tj=bivalent temperature	COPd <u>2.50</u> -
Tj=operating limit	Pdh <b>6.36</b> kW	Tj=operating limit	COPd 2.30 -
Declared capacity for heating / Warmer season, at indoor  Declared coefficient of performance / Warmer season, at indoor			
temperature 20°C and outdoor temperatu		temperature 20°C and outdoor temperature	ature Tj
Tj=2°C	Pdh <b>9.00</b> kW	Tj=2°C	COPd <b>2.80</b> -
Tj=7°C	Pdh <u>5.79</u> kW	Tj=7°C	COPd <u>5.16</u> -
Tj=12°C Ti=bivalent temperature	Pdh 3.95 kW Pdh 9.00 kW	Tj=12°C Tj=bivalent temperature	COPd 7.39 - COPd 2.80 -
Tj=operating limit	Pdh <b>6.36</b> kW	Tj=plvalent temperature	GOPd <b>2.30</b> -
Declared capacity for heating / Colder se		Declared coefficient of performance /	
temperature 20°C and outdoor temperature		temperature 20°C and outdoor temperature 7°C	
Tj=-7°C  Tj=2°C	Pdh	│  Tj=−7°C │  Ti=2°C	COPd
Tj=7°C	Pdh - kW	Ti=7°C	COPd
Tj=12°C	Pdh - kW	Tj=12℃	COPd
Tj=bivalent temperature	Pdh - kW	Tj=bivalent temperature	COPd
Tj=operating limit	Pdh - kW	Tj=operating limit	COPd
<u>Tj=−15°C</u>	Pdh - kW		COPd
Bivalent temperature		Operating limit temperature	
heating / Average	Tbiv <u>-10</u> °C	heating / Average	Tol <u>-15</u> ℃
heating / Warmer	Tbiv 2 °C	heating / Warmer	Tol <u>-15</u> °C
heating / Colder	Tbiv - °C	heating / Colder	Tol
Cycling interval capacity Cycling interval efficiency			
for cooling	Pcycc - kW	for cooling	EERcyc
for heating	Pcych - kW	for heating	COPcyc
Degradation coefficient		Down detice as efficient	
cooling	Cdc <b>0.25</b> -	Degradation coefficient heating	Cdh <b>0.25</b> -
oodin's	040 0120	nodeng	oun oizo
Electric power input in power modes other		Annual electricity consumption	
off mode	Poff 5 W	cooling	Qce <u>531</u> kWh/a
standby mode thermostat-off mode	Psb	heating / Average heating / Warmer	Qhe <b>2289</b> kWh/a Qhe <b>2251</b> kWh/a
thormostat on mode	Pto(heating) 17 W	heating / colder	Qhe - kWh/a
crankcase heater mode	Pck <b>0</b> W		
Capacity control(indicate one of three op	tions)	Other items	Lwa <b>63</b> dB(A)
		Sound power level(indoor) Sound power level(outdoor)	Lwa 63 dB(A) Lwa 70 dB(A)
fixed	No	Global warming potential	GWP 1975 kgCO2eq.
staged	No	Rated air flow(indoor)	- <b>1470</b> m3/h
variable	Yes	Rated air flow(outdoor)	- <b>4500</b> m3/h
O and the destruction of the second of the s	Name and 11 Co.	and for the control of the control o	
Contact details for obtaining more information Mitsul	Name and address of the m bishi Heavy Industries Air-Condition	anufacturer or of its authorised representative.	
5 The Square, Stockley Park, Uxbridge, Middlesex, UB11 1ET,			
	d Kingdom		
i I			