

Outdoor unit		RXP20N5V1B9					
Indoor unit		FTXP20N5V1B9					
Function				Heating season			
Охлаждане		Да		Average (mandatory)		Да	
Отопление		Да		Warmer (if designated)		Да	
				Colder (if designated)		Не	
Item	Symbol	Value	Тяло	Item	Symbol	Value	Тяло
Design Load				Seasonal efficiency			
Охлаждане	Pdesignc	2.00	kW	Охлаждане	SEER	7.20	-
heating / Average	Pdesignh	2.20	kW	heating / Average	SCOP / A	4.65	-
heating / Warmer	Pdesignh	1.18	kW	heating / Warmer	SCOP / W	5.44	-
heating / Colder	Pdesignh		kW	heating / Colder	SCOP / C		-
Обявен капацитет* за охлаждане при вътрешна температура 27(19) °C и външна температура Tj				Обявен капацитет* за охлаждане при вътрешна температура 27(19) °C и външна температура Tj			
Tj = 35 °C	Pdc	2.00	kW	Tj = 35 °C	EERd	3.75	-
Tj = 30 °C	Pdc	1.47	kW	Tj = 30 °C	EERd	6.06	-
Tj = 25 °C	Pdc	1.23	kW	Tj = 25 °C	EERd	9.65	-
Tj = 20 °C	Pdc	1.30	kW	Tj = 20 °C	EERd	11.5	-
Declared capacity* for heating / Average season , at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance* / Average season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7 °C	Pdh	1.95	kW	Tj = -7 °C	COPd	3.39	-
Tj = 2 °C	Pdh	1.18	kW	Tj = 2 °C	COPd	4.74	-
Tj = 7 °C	Pdh	0.950	kW	Tj = 7 °C	COPd	5.62	-
Tj = 12 °C	Pdh	1.06	kW	Tj = 12 °C	COPd	7.02	-
Tj = Bivalent temperature	Pdh	1.95	kW	Tj = Bivalent temperature	COPd	3.39	-
Tj = operating limit	Pdh	2.05	kW	Tj = operating limit	COPd	2.00	-
Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance* / Warmer season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = 2 °C	Pdh	1.18	kW	Tj = 2 °C	COPd	4.74	-
Tj = 7 °C	Pdh	0.950	kW	Tj = 7 °C	COPd	5.62	-
Tj = 12 °C	Pdh	1.06	kW	Tj = 12 °C	COPd	7.02	-
Tj = Bivalent temperature	Pdh	1.18	kW	Tj = Bivalent temperature	COPd	4.74	-
Tj = operating limit	Pdh	2.05	kW	Tj = operating limit	COPd	2.00	-
Declared capacity* for heating / Colder season , at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance* / Colder season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7 °C	Pdh		kW	Tj = -7 °C	COPd		-
Tj = 2 °C	Pdh		kW	Tj = 2 °C	COPd		-
Tj = 7 °C	Pdh		kW	Tj = 7 °C	COPd		-
Tj = 12 °C	Pdh		kW	Tj = 12 °C	COPd		-
Tj = Bivalent temperature	Pdh		kW	Tj = Bivalent temperature	COPd		-
Tj = operating limit	Pdh		kW	Tj = operating limit	COPd		-
Tj = -15 °C	Pdh		kW	Tj = -15 °C	COPd		-
Bivalent temperature				operating limit			
heating / Average	Tbiv	-7.0	°C	heating / Average	Tol	-15	°C
heating / Warmer	Tbiv	2	°C	heating / Warmer	Tol	-15	°C
heating / Colder	Tbiv		°C	heating / Colder	Tol		°C
Cycling interval capacity				Cycling interval efficiency			
for cooling	Pcyc		kW	for cooling	EERcyc		-
for heating	Pcyh		kW	for heating	COPcyc		-
Degradation co-efficient cooling**	Cdc	0.25	-	Degradation co-efficient cooling**	Cdh	0.25	-
Electric power input in power models other than 'active mode'				Annual electricity consumption			
Off mode	Poff	0.001	kW	Охлаждане	QCE	97	kWh/a
Standby mode	Psb	0.001	kW	heating / Average	QHE	663	kWh/a
Thermostat-off mode	Pto	0	kW	heating / Warmer	QHE	303	kWh/a
Crankcase heater mode	Pck	0	kW	heating / Colder	QHE		kWh/a
Capacity control				Other items			
fixed	N			Sound power level (indoor/outdoor)	LWA	55.0 / 60.0	db(A)
staged	N			Global warming potential	GWP	675.0	kgCO ₂ eq.
variable	N			Rated air flow (indoor/outdoor)		9.6 / 27.6	m ³ /min
Contact details for obtaining more information				Daikin Europe N.V. Zandvoordestraat 300, B-8400 Oostende, Belgium			

* for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.

** if default Cd = 0.25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.