

Outdoor unit	RXC60EV1B		
Indoor unit	FTXC60EV1B		
Function			
Охлаждане	Да		
Отопление	Да		
	Average (mandatory) Warmer (if designated) Colder (if designated)		
	Да Да Не		
Item	Symbol	Value	Тяло
Design Load			
Охлаждане heating / Average	Pdesignc	6.2	kW
heating / Warmer	Pdesignh	4.1	kW
heating / Colder	Pdesignh	5.5	kW
	Pdesignh	2.30	kW
Обявен капацитет* за охлаждане при вътрешна температура 27(19) °C и външна температура Tj			
Tj = 35°C	Pdc	6.21	kW
Tj = 30°C	Pdc	4.73	kW
Tj = 25°C	Pdc	3.08	kW
Tj = 20°C	Pdc	2.30	kW
Declared capacity* for heating / Average season , at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7°C	Pdh	3.63	kW
Tj = 2°C	Pdh	2.16	kW
Tj = 7°C	Pdh	1.74	kW
Tj = 12°C	Pdh	1.78	kW
Tj = Bivalent temperature	Pdh	3.63	kW
Tj = operating limit	Pdh	3.30	kW
Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and outdoor temperature Tj			
Tj = 2°C	Pdh	5.53	kW
Tj = 7°C	Pdh	3.65	kW
Tj = 12°C	Pdh	1.78	kW
Tj = Bivalent temperature	Pdh	5.53	kW
Tj = operating limit	Pdh	5.53	kW
Declared capacity* for heating / Colder season , at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7°C	Pdh		kW
Tj = 2°C	Pdh		kW
Tj = 7°C	Pdh		kW
Tj = 12°C	Pdh		kW
Tj = Bivalent temperature	Pdh		kW
Tj = operating limit	Pdh		kW
Tj = -15°C	Pdh		kW
Bivalent temperature			
heating / Average	Tbiv	-7	°C
heating / Warmer	Tbiv	2	°C
heating / Colder	Tbiv	0	°C
Cycling interval capacity			
for cooling	Pcyc		kW
for heating	Pcych		kW
Degradation co-efficient cooling**	Cdc	0.25	-
Electric power input in power models other than 'active mode'			
Off mode	Poff	0.002	kW
Standby mode	Psb	0.002	kW
Thermostat-off mode	PTO	0.066	kW
Crankcase heater mode	PCK	0	kW
Annual electricity consumption			
Охлаждане	QCE	339	kWh/a
heating / Average	QHE	1353	kWh/a
heating / Warmer	QHE	1439	kWh/a
heating / Colder	QHE		kWh/a
Capacity control			
fixed	N		
staged	N		
variable	N		
Contact details for obtaining more information	Daikin Europe N.V. Zandvoordestraat 300, B-8400 Oostende, Belgium		

* for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.

** if default Cd = 0.25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.