Outdoor unit	RXC25BV1B							
Indoor unit	FTXC25BV1B							
Function				Heating season	_			
Cooling	Yes			Average (mandatory)	Yes			
Heating	Yes			Warmer (if designated)	Yes No			
				Colder (if designated)	INO			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit	
Design Load			_	Seasonal efficiency				
Cooling	Pdesignc	2.57	kW	Cooling	SEER	6.84	-	
heating / Average heating / Warmer	Pdesignh Pdesignh	2.23 2.05	kW kW	heating / Average heating / Warmer	SCOP / A SCOP / W	4.45 5.81		
heating / Colder	Pdesignh	2.00	kW	heating / Colder	SCOP/C	0.01	-	
				16	•	<u>.</u>		
Declared capacity* for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj				Declared energy efficiency ratio*, at indoor temper	Declared energy efficiency ratio*, at indoor temperature 27(19) °C and outdoor temperature Tj			
Ti = 35°C	Pdc	2.57	kW	Ti = 35°C	EERd	3.28	-	
Tj = 30°C	Pdc	1.78	kW	Tj = 30 ° C	EERd	5.55	-	
Tj = 25°C	Pdc	1.29	kW	Tj = 25°C	EERd	9.09	-	
Tj = 20°C	Pdc	1.35	kW	Tj = 20°C	EERd	11.91	ŀ	
Declared capacity* for heating / Average season , at indoor temperature 20 °C				Declared coefficient of performance* / Average season, at indoor temperature 20 °C and outdoor				
and outdoor temperature Tj	lo.u.	4 07	1111	temperature Tj	OOD.I	0.00		
Tj = -7°C Tj = 2°C	Pdh Pdh	1.97 1.20	kW kW	Tj = -7°C Tj = 2°C	COPd COPd	3.06 4.35	Ĭ.	
Tj = 7°C	Pdh	0.90	kW	T  = 7°C	COPd	6.08	-	
Tj = 12°C	Pdh	1.12	kW	Tj = 12°C	COPd	7.57	-	
Tj = bivalent temperature	Pdh	1.97	kW	Tj = bivalent temperature	COPd	3.06	-	
Tj = operating limit	Pdh	1.03	kW	Ti = operating limit	COPd	1.92	F	
Declared capacity* for heating / Warmer season , at indoor temperature 20 °C				Declared coefficient of performance* / Warmer season, at indoor temperature 20 °C and outdoor				
and outdoor temperature Tj	Dale	0.05	1.34/	temperature Tj	COD4	0.50		
Tj = 2°C Ti = 7°C	Pdh Pdh	2.05 1.25	kW kW	Tj = 2°C Tj = 7°C	COPd COPd	3.56 5.77	Ī	
Tj = 12°C	Pdh	1.12	kW	Tj = 12°C	COPd	7.63	-	
$T_j$ = bivalent temperature	Pdh	2.05	kW	Tj = bivalent temperature	COPd	3.56	-	
Tj = operating limit	Pdh		kW	Tj = operating limit	COPd		-	
Declared capacity* for heating / Colder season , at indoor temperature 20 °C and				Declared coefficient of performance* / Colder seas	on, at indoo	r temperature 20	°C and outdoor	
outdoor temperature Tj				temperature Tj				
Tj = -7°C	Pdh		kW	Tj = -7°C	COPd		-	
Tj = 2°C Ti = 7°C	Pdh Pdh		kW kW	Tj = 2°C Ti = 7°C	COPd COPd		Ī.	
Ti = 12°C	Pdh		kW	Tj = 12°C	COPd			
Tj = bivalent temperature	Pdh		kW	Tj = bivalent temperature	COPd		-	
Tj = operating limit	Pdh		kW	Tj = operating limit	COPd		-	
Tj = -15°C	Pdh		kW	Ti = -15°C	COPd		-	
Bivalent temperature				Operating limit temperature	_			
heating / Average	Tbiv		°C	heating / Average	Tol	-14	l∘c	
heating / Warmer heating / Colder	Tbiv Tbiv	2	l∘c ∘c	heating / Warmer heating / Colder	Tol Tol		°C	
	1.2		1	1				
Cycling interval capacity	ln		1.147	Cycling interval efficiency	leen.			
for cooling for heating	Pcycc Pcych		kW kW	for cooling for heating	EERcyc COPcyc			
Degradation co-efficient cooling**	Cdc	0.25	-	Degradation co-efficient cooling**	Cdh	0.25	-	
Electric power input in power models other	diamination and dist							
off mode		0.002	kW	Annual electricity consumption Cooling	<b>-</b> -	132	kWh/a	
on mode	Poff	0.002			QCE	. 52		
standby mode	<sup>P</sup> sb	0.002	kW	heating / Average	QHE	700	kWh/a	
	Su				<u>~⊓⊏</u>			
thermostat-off mode	PTO	0.0	kW	heating / Warmer	QHE	494	kWh/a	
crankcase heater mode		0.0	kW	heating / Colder			kWh/a	
Cranicase ricator mode	PCK	0.0		licating / Golder	QHE		KVVII/ a	
		_	_					
Capacity control				Other items			Lucia	
fixed	N			Sound power level (indoor/outdoor)	└WA	54 / 58	db(A)	
staged	N			Global warming potential	GWP	675		
					J	,,,	kgCO2eq.	
variable	Υ			Rated air flow (indoor/outdoor)	}	10.8 / 26.3	<sub>m</sub> 3 <sub>/min</sub>	
	DAIKIN EUROPE							
Contact details for obtaining more information	Zandvoordestra B-8400 Oostend							
	Belgium							

\* for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.

\*\* if default Cd = 0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating of cooling cycling test value is required.