## Information sheet (Lot.10)

This information includes the results of calculation of the seasonal energy consumption and efficiency for air conditioner in regards to ErP pursuant to the Commission Regulation(EU) No.206/2012 and No.626/2011.

Information to identify the model(s) to which the information relates to:

AIR CONDITIONER
TYPE : SINGLE SPLIT
WALL MOUNTED
Indoor unit(s) : ASHG07KGTB
Outdoor unit : AOHG07KGCA
BRAND : GENERAL

N/A = Not Applicable

Function					
Cooling	Yes	Average	Yes		
Heating	Yes	Warmer	Yes		
	Colder	No			

Design load			Seasonal efficiency				
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Cooling	Pdesignc	2.0	kW	Cooling	SEER	8.52	-
Heating/Average	Pdesignh	2.3	kW	Heating/Average	SCOP/A	5.12	-
Heating/Warmer	Pdesignh	1.2	kW	Heating/Warmer	SCOP/W	6.44	-
Heating/Colder	Pdesignh	N/A	kW	Heating/Colder	SCOP/C	N/A	-

Cooling							
Declared capacity for cooling, at indoor temperature 27 (19) °C and outdoor temperature Tj			Declared energy efficiency ratio, at indoor temperature 27 (19) °C and outc	loor temper	ature Tj		
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = 35°C	Pdc	2.00	kW	Tj = 35°C	EER d	5.00	-
Tj = 30°C	Pdc	1.47	kW	Tj = 30°C	EER d	6.90	-
Tj = 25°C	Pdc	1.15	kW	Tj = 25°C	EER d	10.85	-
Tj = 20°C	Pdc	1.15	kW	Tj = 20°C	EER d	13.45	-

Heating/Average							
Declared capacity for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj			Declared coefficient of performance/Average season, at indoor temperature 20 °C and outdoor temperature Tj				
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = -7°C	Pdh	2.03	kW	Tj = -7°C	COPd	3.35	-
Tj = 2°C	Pdh	1.24	kW	Tj = 2°C	COPd	5.15	-
Tj = 7°C	Pdh	0.86	kW	Tj = 7°C	COPd	6.35	-
Tj = 12°C	Pdh	0.93	kW	Tj = 12°C	COPd	8.31	-
Tj = bivalent temperature	Pdh	2.03	kW	Tj = bivalent temperature	COPd	3.35	-
Tj = operating limit	Pdh	2.01	kW	Tj = operating limit	COPd	2.72	-

Heating/Warmer							
Declared capacity for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj			Declared coefficient of performance/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = 2°C	Pdh	1.24	kW	Tj = 2°C	COPd	5.15	-
Tj = 7°C	Pdh	0.86	kW	Tj = 7°C	COPd	6.35	-
Tj = 12°C	Pdh	0.93	kW	Tj = 12°C	COPd	8.32	-
Tj = bivalent temperature	Pdh	1.24	kW	Tj = bivalent temperature	COPd	5.15	-
Tj = operating limit	Pdh	2.01	kW	Tj = operating limit	COPd	2.72	-

Heating/Colder							
Declared capacity for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj			Declared coefficient of performance/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = -7°C	Pdh	N/A	kW	Tj = -7°C	COPd	N/A	-
Tj = 2°C	Pdh	N/A	kW	Tj = 2°C	COPd	N/A	-
Tj = 7°C	Pdh	N/A	kW	Tj = 7°C	COP d	N/A	-
Tj = 12°C	Pdh	N/A	kW	Tj = 12°C	COPd	N/A	-
Tj = bivalent temperature	Pdh	N/A	kW	Tj = bivalent temperature	COP d	N/A	-
Tj = operating limit	Pdh	N/A	kW	Tj = operating limit	COP d	N/A	-
Tj=-15°C	Pdh	N/A	kW	Tj = -15°C	COPd	N/A	-

Bivalent temperature			Operating limit temperature				
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Heating/Average	Tbiv	-7	°C	Heating/Average	Tol	-15	°C
Heating/Warmer	Tbiv	2	°C	Heating/Warmer	Tol	-15	°C
Heating/Colder	Tbiv	N/A	°C	Heating/Colder	Tol	N/A	°C

Cycling interval capacity			Cycling interval efficiency				
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
For cooling	Pcycc	N/A	kW	For cooling	EERcyc	N/A	a
For heating	Pcych	N/A	kW	For heating	COPcyc	N/A	
Degradation coefficient cooling	Cdc	0.25	-	Degradation coefficient heating	Cdh	0.25	-

Electric power input in power modes other than 'active mode'			Annual electricity consumption				
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Off mode (Cooling/Heating)	P <sub>OFF</sub>	1.0/1.0	W	Cooling	Q <sub>CE</sub>	82	kWh/a
Standby mode (Cooling/Heating)	P <sub>SB</sub>	1.0/1.0	W	Heating/Average	$Q_{HE}$	628	kWh/a
Thermostat-off mode (Cooling/Heating)	P <sub>TO</sub>	5.0/8.0	W	Heating/Warmer	$Q_{HE}$	268	kWh/a
Crankcase heater mode (Cooling/Heating)	P <sub>CK</sub>	0.0/0.0	W	Heating/Colder	$Q_{HE}$	N/A	kWh/a

Capacity control	Other items				
Item	Y/N	Item	Symbol	Value	Unit
Fixed	No	Sound power level (Indoor/Outdoor)	L <sub>WA</sub>	54.0/61.0	dB(A)
Staged	No	Global warming potential	GWP	675	kgCO₂eq.
Variable	Yes	Rated air flow (Indoor/Outdoor)	-	650/1610	m³/h

·	
Contact details for obtaining many information	FUJITSU GENERAL LIMITED
Contact details for obtaining more information	3-3-17, Suenaga, Takatsu-ku, Kawasaki, 213-8502, Japan

V20121214