Information to identify the model(s) to v		If function includes heating: Indicate	the heating season the
Indoor unit model name SRK63ZR-W		information relates to. Indicated values should relate to one	
Outdoor unit model name	SRC63ZR-W	heating season at a time. Include at	least the heating season 'Average'.
		<u> </u>	
Function(indicate if present)	V	Average(mandatory)	Yes
cooling	Yes	Warmer(if designated)	Yes
heating	Yes	Colder(if designated)	No
Itom	svmbol value unit	Itam	symbol value class
Item Design load	symbol value unit	Item Seasonal efficiency and energy effici	
cooling	Pdesignc 6.30 kW	cooling	SEER 8.10 A++
heating / Average	Pdesignh 5.40 kW	heating / Average	SCOP/A 4.70 A++
heating / Warmer	Pdesignh 6.60 kW	heating / Warmer	SCOP/W 6.00 A+++
heating / Colder	Pdesignh - kW	heating / Colder	SCOP/C
Traditing / Corasi	T GOODS III	modeling / Obliger	unit
Declared capacity at outdoor temperatu	ure Tdesignh	Back up heating capacity at outdoor	temperature Tdesignh
heating / Average (-10°C)	Pdc 5.40 kW	heating / Average (-10°C)	elbu 0 kW
heating / Warmer (2°C)	Pdc 6.60 kW	heating / Warmer (2°C)	elbu 0 kW
heating / Colder (-22°C)	Pdc - kW	heating / Colder (-22°C)	elbu - kW
Declared capacity for cooling, at indoor	temperature 27(19)°C and	Declared energy efficiency ratio, at i	ndoor temperature 27(19)°C and
outdoor temperature Tj		outdoor temperature Tj	
Tj=35°C	Pdc 6.30 kW	Tj=35°C	EERd 3.87 -
Tj=30°C	Pdc 4.64 kW	Tj=30°C	EERd 5.50 -
Tj=25°C	Pdc 2.98 kW	Tj=25°C	EERd 9.67 -
Tj=20°C	Pdc 1.60 kW	Tj=20°C	EERd 19.00 -
D			
Declared capacity for heating / Average season, at indoor temperature 20°C and outdoor temperature Tj Declared coefficient of performance / Average season, at indoor temperature 20°C and outdoor temperature Tj			
temperature 20°C and outdoor tempera $T_{j=-7}^{\circ}$ C		Ti=-7°C Ti=-7°C	
	Pdh 4.78 kW Pdh 2.80 kW	Ti=2°C	
1]-2	Pdh 2.80 kW		COPd 4.73 - COPd 6.00 -
Tj=12°C	Pdh 1.87 kW	Ti=12°C	COPd 6.50 -
Tj=bivalent temperature	Pdh 5.40 kW	Ti=bivalent temperature	COPd 2.60 -
Tj=blvalent temperature Tj=operating limit	Pdh 4.90 kW	Tj=plvalent temperature	COPd 2.40 -
ij-operating illilit	Full 4.50 KW	IJ-operating innit	00Fd 2.40
Declared capacity for heating / Warmer	season, at indoor	Declared coefficient of performance	/ Warmer season, at indoor
temperature 20°C and outdoor tempera		temperature 20°C and outdoor temperature	
Tj=2°C	Pdh 6.60 kW	_{Ti=2} °C	COPd 2.90 -
Tj=7°C	Pdh 4.25 kW	│ Ti=7°C	COPd 5.54 -
Tj=12°C	Pdh 1.89 kW	Ti=12°C	COPd 7.31 -
Tj=bivalent temperature	Pdh 6.60 kW	Tj=bivalent temperature	COPd 2.90 -
Tj=operating limit	Pdh 4.90 kW	Tj=operating limit	COPd 2.40 -
Declared capacity for heating / Colder		Declared coefficient of performance	
temperature 20°C and outdoor tempera		temperature 20°C and outdoor temperature	
Tj=-7°C	Pdh - kW	Tj=-7°C	COPd <u>-</u> -
Tj=2°C	Pdh - kW	Tj=2°C	COPd <u>-</u> -
Tj=7°C	Pdh - kW	Tj=7°C	COPd
Tj=12°C	Pdh - kW	Tj=12°C	COPd
Tj=bivalent temperature	Pdh - kW	Tj=bivalent temperature	COPd
Tj=operating limit	Pdh - kW	Tj=operating limit	COPd
<u>Tj=−15°C</u>	Pdh - kW		COPd - -
Bivalent temperature		Operating limit temperature	
heating / Average	Tbiv -10 °C	heating / Average	Tol -15 ℃
heating / Warmer	Tbiv 2 °C	heating / Warmer	Tol -15 °C
heating / Colder	Tbiv - °C	heating / Colder	Tol - ℃
, , , , , , , , , , , , , , , , , , ,			
Cycling interval capacity	<u></u>	Cycling interval efficiency	
for cooling	Pcycc - kW	for cooling	EERcyc
for heating	Pcych - kW	for heating	COPcyc
Degradation coefficient	0.1	Degradation coefficient	0.11
cooling	Cdc 0.25 -	heating	Cdh 0.25 -
Electric power input in power modes oth	har than 'active made'	Annual electricity consumption	
off mode	Poff 5 W	cooling	Qce 273 kWh/a
standby mode	Psb 5 W	heating / Average	Qhe 1608 kWh/a
thermostat-off mode	Pto(cooling) 16 W	heating / Warmer	Qhe 1539 kWh/a
anormostat on mode	Pto(heating) 17 W	heating / colder	Qhe - kWh/a
crankcase heater mode	Pck 0 W	ricating / coldor	Killy d
Capacity control(indicate one of three of	options)	Other items	
		Sound power level(indoor)	Lwa 56 dB(A)
		Sound power level(outdoor)	Lwa 64 dB(A)
fixed	No	Global warming potential	GWP 675 kgCO2eq.
staged	No	Rated air flow(indoor)	- 1230 m3/h
variable	Yes	Rated air flow(outdoor)	- 2490 m3/h
Contact details for obtaining		ufacturer or of its authorised representative	3.
	subishi Heavy Industries Air-Conditionir	•	
	ne Square, Stockley Park, Uxbridge, Mi	iaaiesex, UBTT TET,	
Unit	ed Kingdom		