Information to identify the model(s) to which the information relates to:			If function includes heating: Indicate the heating season the			
Indoor unit model name SRK35ZS-WT		information relates to. Indicated values should relate to one				
Outdoor unit model name	SRC35ZS-	W	heating season at a time. Include at least th	e heating seas	son 'Average	· .
Function(indiants if measure)			1 A	Vaa		
Function(indicate if present) cooling	Yes		Average(mandatory) Warmer(if designated)	Yes Yes		
heating	Yes		Colder(if designated)	No		
	103					
Item	symbol	value unit	Item	symbol	value	class
Design load			Seasonal efficiency and energy efficiency cla			
cooling	Pdesignc	3.50 kW	cooling	SEER	8.40	A++
heating / Average	Pdesignh	3.00 kW	heating / Average	SCOP/A	4.70	A++
heating / Warmer	Pdesignh	3.70 kW	heating / Warmer	SCOP/W	6.00	A+++
heating / Colder	Pdesignh	- kW	heating / Colder	SCOP/C	-	-
	Talaalaala		Bask on basting and its at a tide of the sec	atura Talaa'aa	b	unit
Declared capacity at outdoor temperature heating / Average (-10°C)	Pdc	3.00 kW	Back up heating capacity at outdoor temper heating / Average (-10°C)	elbu	0	kW
heating / Warmer (2°C)	Pdc Pdc	3.70 kW	heating / Warmer (2°C)	elbu	0	kW
heating / Colder (-22°C)	Pdc	- kW	heating / Colder (-22°C)	elbu	-	kW
	1 40	K		CIDU	1	
Declared capacity for cooling, at indoor temperature 27(19)°C and Declared energy efficiency ratio, at indoor temperature 27(19)°C and						
outdoor temperature Tj	· ·		outdoor temperature Tj			_
Tj=35°C	Pdc	3.50 kW	Tj=35°C	EERd	3.82	-
Tj=30°C	Pdc	2.58 kW	Tj=30°C	EERd	5.82	-
Tj=25°C	Pdc	1.60 kW	Tj=25°C	EERd	11.20	-
Tj=20°C	Pdc	1.07 kW	Tj=20°C	EERd	18.50	-
Declared capacity for heating / Average s			Declared coefficient of performance / Avera	•	indoor	
temperature 20°C and outdoor temperatur		0.05	temperature 20°C and outdoor temperature $T = 7^{\circ}$ C	5	0.50	7
Tj=-7°C	Pdh	2.65 kW	Tj=-7°C	COPd	2.50	-
Tj=2°C	Pdh	1.62 kW	Tj=2°C	COPd	4.92	-
Tj=7°C Tj=12°C	Pdh	<u>1.04</u> kW 1.16 kW	Tj=7°C Tj=12°C	COPd COPd	6.10	-
	Pdh		-		7.86	-
Tj=bivalent temperature	Pdh Pdh	3.00 kW 2.52 kW	Tj=bivalent temperature Tj=operating limit	COPd COPd	2.40 2.10	-
Tj=operating limit	Fun	2.32 KW		COFu	2.10	_
Declared capacity for heating / Warmer se	eason at indoor		Declared coefficient of performance / Warm	er season at	indoor	
temperature 20°C and outdoor temperature			temperature 20°C and outdoor temperature			
Tj=2℃	Pdh	3.70 kW	Tj=2°C	COPd	2.80	7–
Tj̃=7℃	Pdh	2.38 kW	Ti=7°C	COPd	5.20	7-
Tj=12°C	Pdh	1.16 kW	Tj=12°C	COPd	7.86	7-
Tj=bivalent temperature	Pdh	3.70 kW	Tj=bivalent temperature	COPd	2.80	-
Tj=operating limit	Pdh	2.52 kW	Tj=operating limit	COPd	2.10	-
Declared capacity for heating / Colder sea			Declared coefficient of performance / Colde		ndoor	
temperature 20°C and outdoor temperatur			temperature 20°C and outdoor temperature			7
Tj=−7°C	Pdh	- kW	Tj=-7°C	COPd	-	-
Tj=2°C	Pdh	- kW	Tj=2°C	COPd	-	-
Tj=7°C	Pdh	- kW	Tj=7°C	COPd	-	-
Tj=12°C	Pdh	- kW	Tj=12°C	COPd	-	-
Tj=bivalent temperature	Pdh	- kW	Tj=bivalent temperature	COPd	-	-
Tj=operating limit	Pdh	- kW	Tj=operating limit	COPd	-	-
Tj=-15°C	Pdh	- kW	Tj=−15°C	COPd	-	-
Bivalent temperature			Operating limit temperature			
heating / Average	Tbiv	-10 °C	heating / Average	Tol	-15	°C
heating / Warmer	Tbiv	2 °C	heating / Warmer	Tol	-15	č
heating / Colder	Tbiv	- °C	heating / Colder	Tol	-15	°C
						1.2
Cycling interval capacity			Cycling interval efficiency			_
for cooling	Pcycc	- kW	for cooling	EERcyc	-	-
for heating	Pcych	- kW	for heating	COPcyc	-	-
Degradation coefficient	а. Г		Degradation coefficient			7
cooling	Cdc	0.25 –	heating	Cdh	0.25	-
Electric power input in power modes other	r than 'active mod	lo'	Annual electricity consumption			
off mode	Poff	4 W	cooling	Qce	146	kWh∕a
standby mode	Psb	4 W	heating / Average	Qhe	895	kWh/a
thermostat-off mode	Pto	10 W	heating / Warmer	Qhe	863	kWh∕a
crankcase heater mode	Pck	0 W	heating / colder	Qhe	-	kWh∕a
					•	
Capacity control(indicate one of three opt	ions)		Other items			_
			Sound power level(indoor)	Lwa	54	dB(A)
			Sound power level(outdoor)	Lwa	61	dB(A)
fixed	No		Global warming potential	GWP	675	kgCO2eq.
staged	No		Rated air flow(indoor)	-	678	m3/h
variable	Yes		Rated air flow(outdoor)	-	1890	m3/h
Contact details for obtaining			urer or of its authorised representative.			
	•	ries Air-Conditioning Eu				
	Square, Stockley I Kingdom	Park, Uxbridge, Middles	sex, UBIT IET,			
Onited	Tanguoni					