Information to identify the model(s) to which the information relates to: Indoor unit model name SRK25ZSX-WT			If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one				
Outdoor unit model name	SRC25ZSX-W		heating season at a time. Include at leas			o'.	
Function(indicate if present)			Average(mandatory)	Yes	Yes		
cooling	Yes		Warmer(if designated)	Yes			
heating	Yes		Colder(if designated)	No			
Item	symbol value	unit	Item	symbol	value	class	
Design load			Seasonal efficiency and energy efficience			T -	
cooling	Pdesignc 2.5		cooling	SEER SCOP/A	10.30	A+++	
heating / Average heating / Warmer	Pdesignh 3.0 Pdesignh 4.2		heating / Average heating / Warmer	SCOP/W	5.20 6.60	A+++ A+++	
heating / Colder	Pdesignh -		heating / Colder	SCOP/C	-	-	
						unit	
Declared capacity at outdoor tempera heating / Average (-10°C)	ture I designh	00 kW	Back up heating capacity at outdoor ten heating / Average (-10°C)	mperature I designh elbu	0	kW	
heating / Warmer (2°C)	Pdc 4.2		heating / Warmer (2°C)	elbu	0	kW	
heating / Colder (-22°C)	Pdc -		heating / Colder (-22°C)	elbu	-	kW	
07(4)\00							
Declared capacity for cooling, at indoo outdoor temperature Ti	r temperature 27(19) C and	d	Declared energy efficiency ratio, at indo outdoor temperature Ti	or temperature 27	(19) °C and		
Tj=35°C	Pdc 2.5	5 0 kW	Ti=35°C	EERd	5.68	Ī-	
Tj=30°C	Pdc 1.8		Tj=30°C	EERd	8.75]-	
Tj=25°C	Pdc 1.2		Tj=25°C	EERd	14.10		
Tj=20°C	Pdc 1.4	40 kW	Tj=20°C	EERd	20.40	-	
Declared capacity for heating / Avera	ge season, at indoor		Declared coefficient of performance / A	verage season, at	indoor		
temperature 20°C and outdoor temper			temperature 20°C and outdoor temperat			_	
Tj=-7°C	Pdh 2.6		Tj=-7°C	COPd	3.15		
Tj=2°C Tj=7°C	Pdh 1.5 Pdh 1.0		Tj=2°C Tj=7°C	COPd COPd	5.30 6.58	-[
Tj=12°C	Pdh 0.9			COPd	8.30	1_	
Tj=bivalent temperature	Pdh 3.0		Tj=bivalent temperature	COPd	2.69	_	
Tj=operating limit	Pdh 3.0	00 kW	Tj=operating limit	COPd	2.69	-	
Declared capacity for heating / Warmo	or coacon at indoor		Declared coefficient of performance / W	Varmor coasan at	indoor		
temperature 20°C and outdoor temperature			temperature 20°C and outdoor temperat		ildooi		
Tj=2°C	Pdh 4.2		Tj=2°C	COPd	3.30]-	
Tj=7°C	Pdh 2.7		Tj=7°C	COPd	5.90	_ -	
Tj=12°C Tj=bivalent temperature	Pdh 1.2 Pdh 4.2		Tj=12°C Tj=bivalent temperature	COPd COPd	8.27 3.30	-[
Tj=operating limit	Pdh 4.2		Tj=operating limit	COPd	3.30	_	
Declared capacity for heating / Colde			Declared coefficient of performance / C		ıdoor		
temperature 20°C and outdoor temper Ti=-7°C	Pdh -	kW	temperature 20°C and outdoor temperat	ture IJ COPd	_	7_	
Tj=2°C	Pdh -		Ti=2°C	COPd	-	_	
Tj=7℃	Pdh -		Tj=7°C	COPd	-	_	
Tj=12°C	Pdh -		Tj=12°C	COPd	-		
Tj=bivalent temperature Tj=operating limit	Pdh -	 :::::	Tj=bivalent temperature Tj=operating limit	COPd COPd	-	-	
Tj=-15°C	Pdh -		Tj=-15°C	COPd	-	-	
Bivalent temperature	TIC. 4	0 00	Operating limit temperature	T.1	40	J°c	
heating / Average heating / Warmer	Tbiv -1 Tbiv 2		heating / Average heating / Warmer	Tol Tol	-10 2	_°C	
heating / Colder	Tbiv -		heating / Colder	Tol	-	_c ⊙	
Cycling interval capacity	D	1.34/	Cycling interval efficiency	EED		7	
for cooling for heating	Pcycc <u>-</u> Pcych -	——:`:::	for cooling for heating	EERcyc COPcyc	-		
To Thousang	. oyo	į	TOT THOUGHTO				
Degradation coefficient			Degradation coefficient			1	
cooling	Cdc 0.2	25 -	heating	Cdh	0.25	-	
Electric power input in power modes of	ther than 'active mode'		Annual electricity consumption				
off mode	Poff 4	W	cooling	Qce	85	kWh/a	
standby mode	Psb 4		heating / Average	Qhe	808	kWh/a	
thermostat-off mode crankcase heater mode	Pto 1.2		heating / Warmer heating / colder	Qhe Qhe	891	kWh∕a kWh∕a	
Crankcase fleater fliode	FCK U	, , , , , , , , , , , , , , , , , , , ,	neating / colder	<u> </u>	<u> </u>	INVVII/ a	
Capacity control(indicate one of three	options)		Other items				
			Sound power level(indoor)	Lwa	<u>55</u>	dB(A)	
fixed	No		Sound power level(outdoor)	Lwa GWP	57 675	dB(A)	
rixed No No No		Global warming potential Rated air flow(indoor)	- GWP	675 732	kgCO2eq. m3/h		
variable			Rated air flow(outdoor)	_	1860	m3/h	
		· · ·					
Contact details for obtaining Miles	Name and addres HIAE SERVICES B.V.	s of the manuf	acturer or of its authorised representative.				
	erikerbergweg 238, Luna Are	enA, 1101 CM A	Amsterdam, Netherlands				
	O.Box 23393 1100 DW Ams						
į l							